



NOTE:

C.I.P. CF BARRIERS SHALL BE 5000 PSI, $\frac{3}{4}$ IN., 685 HP CEMENT CONCRETE.

SECTION THRU CF BARRIERS AT OVERHANG

SCALE: 1" = 1'-0"

NOTES:

1. #A @ X" = Size and spacing of the primary deck slab reinforcement as per Design Tables on Dwg. No. 5.1.30.
2. #B @ X" = Size and spacing of the Additional Overhang Reinforcement as per Design Tables on Dwg. No's. 5.1.34 or 5.1.35.
3. Additional Overhang Reinforcement extension (Lext.) as per Design Tables on Dwg. No's. 5.1.34 and 5.1.35.
4. C = Spacing of longitudinal reinforcement as per Design Tables on Dwg. No. 5.1.30.
5. For details and configuration of CF-PL2 and CF-PL3 barriers, see Chapter 9, Part II of this Bridge Manual.
6. Steel beam superstructure shown. Modify the details to accommodate other superstructure types.
7. The minimum dimension from the center of the PT duct to the edge of the shear connector pocket shall be 9".



LRFD BRIDGE

MANUAL, PART III

**SECTION THRU OVERHANG
FOR CF BARRIERS**

PRECAST CONCRETE DECK PANELS

DATE OF ISSUE
JUNE 2013

DRAWING NUMBER

5.1.29