

V. Appendix A.: Town of Stoughton Energy Audit – Prism Energy Services

TOWN OF STOUGHTON

PRELIMINARY ANALYSIS

AND

RECOMMENDATIONS OF POTENTIAL

ENERGY CONSERVATION MEASURES



1150 Hancock Street, Suite 400 ▲ Quincy, MA 02169
T 617 328-9896 ▲ F 617 328-0496
www.prismenergyservices.com

TOWN OF STOUGHTON

ENERGY CONSERVATION MEASURES

PRELIMINARY ANALYSIS AND RECOMMENDATIONS

CEDAR HILL GOLF COURSE: 1137 Park Street, Stoughton, MA 02072

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Programmable Thermostat

The current electric baseboard unit used in the men's bathroom for heating is controlled manually. It is set at one position unless one person adjusts it. It is left at a high temperature during the heating season, with no automatic control. We propose to install one programmable thermostat in the men's bathroom to setback the temperature from the electric baseboard during the time the facility is unoccupied (Nights during the heating season).

3- Low Flow sink Aerators.

Existing bathroom faucets have a high flow which can be reduced by installing aerators.

We propose to install aerators on each faucet to reduce the GPM per faucet (Where aerators can fit)

4- Kitchen Hood Control

The kitchen ventilation is achieved by a make-up air unit which supplies 100% outside air to the kitchen. This air is then exhausted through the hood to insure no fume is returned into the facility. The make-up air units and the exhaust fan are constant volume. The air supplied to the kitchen needs to be conditioned (cooled or heated depending on the season and setpoints). The kitchen is open in the morning and closes late in the evening. We propose to add controls and variable frequency drives on the make-up air unit and on the exhaust fans motors to modulate based on the smoke and the temperature inside the hood. In addition, a schedule to shut off the make-up air unit and the exhaust fan when the kitchen closes will be put in place to save energy. When the temperature in the hood rises or the amount of smoke increases, the supply and exhaust fans will ramp-up their speed to exhaust the fumes quickly and reduce the temperature in the hood. They will ramp down when the temperature or the smoke in the hood decrease.

5- Demand Control Ventilation

The ventilation system of the main space is made through the air handing unit which brings in fresh air at a constant volume during the day. During some occupied hours, the space occupancy is very low, while during other hours the space occupancy is high.

We propose to regulate the amount of fresh air introduced inside the building based on the occupancy of the space. CO2 sensor will be installed to track and monitor the space occupancy and allow the control system to modulate the dampers based on the need of fresh air inside the building.

6- Install VFD on the RTU

There is one rooftop units serving the facility for cooling and heating some space. We propose to add a control kit with a variable frequency drive to ramp up the motor speed or ramp it down based on meeting the temperature setpoints inside the space, to reduce the electric load on the motors.

COUNCIL ON AGING/SENIOR CENTER

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

CLAPP LIBRARY/HISTORICAL SOCIETY

1- Boiler Replacement

Clapp Library is heated by a hot water 600 MBH boiler which was installed almost 40 years ago. The boiler is old and inefficient. The supply hot water temperature is constant during the heating season, with no capability for hot water reset based on outdoor temperature.

We propose to replace the existing boiler with two 300 MBH condensing boilers (or one 600 MBH condensing boiler) with capability to reset the heating water temperature based on the outdoor air temperature and modulate the boilers based on the building thermal load needs.

2- Programmable Thermostats

The building space temperature is controlled by manual thermostats which are set at one temperature, with no automatic setback. The building is open only two days a week during the day. We propose to install programmable thermostats to control all the spaces and setback the temperature at night and during unoccupied hours.

DPW GARAGE & TRUCK MAINTENANCE GARAGE

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Maintenance Garage& Mechanical Bay Programmable Thermostats

The Maintenance Garage& Mechanical Bay are heated by rooftop units and fan coil units. The space temperature is controlled by manual thermostats which are set at one temperature only with no automatic setback. These facilities are open during the day only, from 7:00 am to 3:00 pm, Monday

through Friday, and very occasionally late in the day or early in the morning when there is snow storms. We propose to install programmable thermostats to control all the fan coil units, rooftop units, and setback the temperature in the spaces they serve during unoccupied hours.

DPW OFFICE AND STORAGE GARAGES

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Main Entrance FCU Programmable Thermostat

The main entrance of the DPW Office is heated by a fan coil unit which is controlled by a manual thermostat, with no option for automatic setback. The building is occupied from 7:00 am to 3:00 pm, M-F. We propose to install a programmable thermostat to control the fan coil unit and setback the temperature at night and during unoccupied hours.

FIRE STATION 2

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Low-Flow Sink Aerators

Existing bathroom faucets have a high flow which can be reduced by installing aerators. We propose to install aerators on each faucet to reduce the GPM per faucet (Where aerators can fit)

3- Dorm Programmable Thermostats – Heating

The dormitory space temperature is controlled by a manual thermostat set at one temperature with no automatic setback option. The space is sometime overheated while unoccupied. We propose to install a programmable thermostats to control the space temperature and setback the temperature during unoccupied hours.

4- Dorm Programmable Thermostats – Cooling

The dormitory space temperature is controlled by a manual thermostat set at one temperature with no automatic setback option. The space is set at a low temperature during unoccupied hours. We propose to install a programmable thermostats to control all the space temperature and set forward the temperature during unoccupied hours.

5- Garage Bay - Programmable Thermostats

The garage bay is heated by gas-fired fan coil units which maintain a comfortable temperature in the bay. The temperature control in the bay is manual, with no option for automatic setback.

We propose to install programmable thermostats to control each gas-fired fan coil unit and setback the space temperature during unoccupied hours (Nights)

FIRE STATION 1

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Replace Heating Hot Water Boiler

The existing heating hot water boiler for Fire station 1 was installed more than forty years ago. It is a gas fired 1.3 MBH boiler. It is old, inefficient and at the end of its useful life. We propose to install 1.2 MBH high efficiency condensing boiler – 92% (or 4 – 300 MBH condensing boilers) with controls for hot water reset based on outdoor air temperature.

3- Add Centralized Cooling

The dormitory is cooled by five AC window units, while the common area is cooled by two AC Window units. There is no option for temperature control for the AC window units. Each of them is manually controlled. The AC Window units are inefficient with poor temperature control. We propose to replace the AC window AC units in the dormitory (Five) with two 3 ton heat pumps and add automatic control for temperature setback. We propose to replace the AC window AC units in the common area (two) with one 3 ton heat pump and add automatic control for temperature setback.

4- Main Common Area Programmable Thermostats:

The main common area is heated with hot water baseboard units. During the heating season, the temperature is so high in the space that the occupants keep the door open to keep the temperature comfortable. There is a manual thermostat which seems not to work properly. We propose to install a programmable thermostat to allow better temperature control of the space and set back the temperature during unoccupied hours.

5- Fire Station 1 Garage Bay - Programmable Thermostats

The garage bay is heated by gas-fired fan coil units which maintain a comfortable temperature in the bay. The temperature control in the bay is manual, with no option for automatic setback.

We propose to install programmable thermostats to control each gas-fired fan coil unit and setback the space temperature during unoccupied hours (Nights)

PUBLIC LIBRARY

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Replace Heating Hot Water Boiler

The existing heating hot water boiler at the public library is probably original to the building construction in 1969. It is a gas fired hot water boiler, rated at 582 MBH input (80% efficiency). It is old, inefficient and at the end of its useful life. We propose to replace it with a new 600 MBH high efficiency condensing boiler – 92% (or 2 – 300 MBH condensing boilers) with controls for hot water reset based on outdoor air temperature.

3- Weatherization

This measure consists of weather-stripping and air sealing main entrance doors which have gaps between their double doors, letting in cold or hot air which need to be conditioned unnecessarily.

4- Demand Control Ventilation

The ventilation system of the main space in the library is performed through the air handling units which brings in fresh air at a constant volume during the day. During some occupied hours, the space occupancy is very low, while during other hours the space occupancy is high.

We propose to regulate the amount of fresh air introduced inside the building based on the occupancy of the space served by each individual air handling unit. CO2 sensor will be installed to track and monitor the space occupancy and allow the control system to modulate the dampers based on the need of fresh air inside the building.

5- Install VFD on Chilled Water Pumps

There are two chilled water pumps which alternate to circulate chilled water to various AHU coils during the cooling season. These pumps are constant flow. Modulating the speed (The load) of the pumps based on the chilled demand will reduce the energy consumed by these pumps. We propose to install two 5 HP VFD (One on each pump) and set them to vary their speed based on the building cooling demand.

6- Install VFD on Heating Hot Water Pumps

There are two heating hot water pumps which alternate to circulate hot water to various AHU coils during the heating season. These pumps are constant flow. Modulating the speed (the load) of the pumps based on the building heating load will reduce the energy consumed by these pumps.

We propose to install two 3 HP VFD (One on each pump) and set them to vary their speed based on the building cooling demand.

7- Chiller Compressors Replacement

The existing chiller which serves the library is old and inefficient, with a very high kW/ton delivered. We propose to replace the chiller compressors with more efficient ones which use less kW/Ton and connect them to the existing condenser and evaporator loops.

8- Install VFDs on AHUs

AHUs which are used to ventilate, heat and cool various area of the library are constant volume. We propose to install variable frequency drives on each of the AHU fan motor to modulate the speed of the fan motors based on the temperature in the space to save electric energy.

PRATTS COURT WATER TREATMENT

1- Lighting:

See Line by line lighting audit in pdf file (Separate file)

2- Programmable Thermostats

The building space temperature is controlled by multiple manual thermostats which are set at different temperature with no automatic setback. The building is open from 7:00 am to 3:00 pm M-F. We propose to install programmable thermostats to control all the spaces and setback the temperature at night and during unoccupied hours.

3- Variable Frequency Drives on Drinking Water Pumps

There are two drinking water pumps at Pratts Court. One is 60 HP with no VFD and another one is 15 HP. They operate during the day only, for eight hours per day. They are constant volume pumps. We propose to add VFDs on these two pumps to modulate their speed based on the demand.

4- PLC Upgrades

The two pumps at Pratts Court are not on the SCADA system. We propose to add them on the Control network and run them automatically all year round based on the demand, with the capability of manual control when needed by the operators.

PUMP STATION #1

1- Variable Frequency Drives on Drinking Water Pumps

There is one drinking water pump at Pump Station #1. The pump motor size is 100 HP with no VFD. We propose to install one 100 HP variable frequency drive on the pump motor.

PUMP STATION #3

1- PLC Control on three 40 HP pump motors

There are three 40 HP pump motors with VFDs. Only one pump can run at a time. We propose to modify the pumps operation by upgrading their control to operate two pumps at a time, a lower speed. This type of operation will lower the overall energy consumption from pump station #3.

PUMP STATION #5

1- VFD On Pump #5

There is one drinking water pump at Pump Station #5. The pump motor size is 60 HP with no VFD. We propose to install one 60 HP variable frequency drive on the pump motor

GODDARD WELL

1- VFD On Pump #7

There is one drinking water pump at Pump Station #7 (Goddard Well). The pump motor size is 20 HP with no VFD. We propose to install one 20 HP variable frequency drive on the pump motor

SEWER PUMPS VFDs

There are three sewer pump motors with no VFD. Each motor is 25 HP. We propose to install three 25 HP variable frequency drive on the pump motors.

POLICE STATION:

1- Low-Flow Sink Aerators

Existing Men's and Women's bathroom faucets have a high flow which can be reduced by installing aerators. We propose to install aerators on each faucet to reduce the GPM per faucet (Where aerators can fit).

2- Cooling System Upgrade

The existing Cooling system consists of ten split systems located on the roof of the building. The installed cooling load totals 27 tons. Each unit has a dedicated space. In recent years, the units have not been delivering enough cooling and portable cooling units have been added to the various spaces. We propose to install two (2) 20 ton condensing units to boost the cooling need of the facility and improve the efficiency of the cooling system. Energy will be saved from the efficiency of the system and by a better control of each zone served by the rooftop units.

3- Demand Control Ventilation

There are ten (10) zones with constant volume air system. Although the police station is open 24/7, some areas can be unoccupied for a long period. We proposed to add CO2 sensors on each zone and add controls on the ventilation system to modulate the fresh air supply based on the zone occupancy. This control system will allow to save energy, while maintaining comfort level, in zones which are not occupied all the time.

ROBERT O'DONNELL MIDDLE SCHOOL

1- Weatherization

There are three double door serving as entrance to the middle school. These doors have gaps which allow air infiltration. The air entering the space needs to be air conditioned, costing a lot of money to the school. We propose to add air sealing and weather-strip the double doors to reduce the amount of air infiltration into the building.

2- New Hot Water Heater

Domestic hot water used by the school is produced by the heating boilers located in the mechanical room of the school. Water is stored in an oversized domestic hot water tank, with lots of heat losses. The boilers need to run when the school is in section, even when there is no need for heating. This type of heating hot water is inefficient.

We propose to replace the hot water tank and the domestic hot water heating system with a small size domestic hot water heater for better efficiency

3- Kitchen Hood Control

The kitchen ventilation is achieved by a two unit ventilators which supplies 100% outside air to the kitchen. This air is then exhausted through the hood to insure no fume is returned into the facility. The make-up air units (unit ventilators) and the exhaust fan are constant volume. The air supplied to the kitchen needs to be conditioned (heated depending on the season and setpoints). The kitchen is open in the morning and closes late in the evening. We propose to add controls and variable frequency drives on the unit ventilators motors unit and on the exhaust fans motor to modulate based on the smoke and the temperature inside the hood. In addition, a schedule to shut off the make-up air unit and the exhaust fan when the kitchen closes will be put in place to save energy. When the temperature in the hood rises or the amount of smoke increases, the supply and exhaust fans will ramp-up their speed to exhaust the fumes quickly and reduce the temperature in the hood. They will ramp down when the temperature or the smoke in the hood decrease.

4- VFDs on HW Pumps

There are two hot water pump motors with no VFD. We propose to add two 3 HP VFD on the two heating hot water pump motors and modulate their speed based on the thermal loads of the spaces they serve.

5- Energy Management System

The existing HVAC control system consists of a combination of old pneumatic controls and a timer for equipment operation and scheduling. These controls are antiquated, lack flexibility and accuracy. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and reset heating hot water based on outdoor air temperature.

6- Demand Control Ventilation

There are approximately fifty (50) unit ventilators serving classrooms. We propose to add CO2 sensors on each unit ventilator and modulate the fresh air introduced into the classrooms based on the occupancy of the space. This will reduce the amount of cold air needed to be heated during the heating season while saving energy at the same time.

GIBBONS ELEMENTARY

1- Burner Electronic Controls

The existing burners have mechanical cam controls on boilers which were installed in 1979. We propose to install electronic controls on the burners to adjust their operation pattern based on the thermal load.

2- VFD on gym AHUs in the Mechanical Room

The Gym AHU motor in the mechanical has no variable frequency drives. We propose to install one 3 HP VFD to modulate the fan motor speed based on the temperature inside the gym.

3- Energy Management System

The existing HVAC control system consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, lack flexibility and accuracy.

During the heating season, when the outdoor temperature is 30 degrees F or below, the heating is overridden and all the HVAC units (Pumps, boilers, UVs) run constantly, including during the unoccupied hours. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and reset heating hot water based on outdoor air temperature. They will also have a better monitoring system which will reduce the run hours on the boilers and the heating systems.

4- Demand Control Ventilation

Gibbons Elementary School has approximately 25 unit ventilators serving classrooms. We propose to add CO2 sensors on each unit ventilator and modulate the fresh air introduced into the classrooms based on the occupancy of the space. This will reduce the amount of cold air needed to be heated during the heating season while saving energy at the same time.

JOSEPH R. DAWE ELEMENTARY

1- Energy Management System

The existing HVAC control system consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, lack flexibility and accuracy. The custodian performs most of the operations manually. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and reset heating hot water based on outdoor air temperature. They will also have a better monitoring system which will reduce the run hours on the boilers and the heating systems.

2- Burner Electronic Controls

The existing burners have mechanical cam controls on boilers which were installed in 1979. We propose to install electronic controls on the burners to adjust their operation pattern based on the thermal load.

3- Programmable Thermostats

One section of the school is cooled by four (4) split systems, ranging from 2 tons to five tons (Total of 11 ton). The space they served are controlled with manual thermostats, with no option for automatic set forward. These spaces are occupied six to eight hours per day only, M-F. We propose to add programmable thermostats to setback the temperature in these spaces during unoccupied hours to save energy and extend the life of the split systems.

4- Kitchen Equipment Conversion

The kitchen equipment run on electricity, including the stoves (four). We propose to convert the existing stoves to natural gas fires stoves since natural gas is available at the school.

WEST ELEMENTARY SCHOOL

1- Kitchen Hood Control

The kitchen ventilation is achieved by a 5 HP make-up air which supplies 100% outside air to the kitchen. This air is then exhausted through the hood to insure no fume is returned into the facility. The make-up air unit and the exhaust fan are constant volume. The air supplied to the kitchen needs to be conditioned (heated depending on the season and setpoints). The kitchen is open in the morning and closes late in the afternoon. We propose to add controls and variable frequency drives on the make-up air unit motor unit and on the exhaust fan motor to modulate based on the smoke and the temperature inside the hood. In addition, a schedule to shut off the make-up air unit and the exhaust fan when the kitchen closes will be put in place to save energy. When the temperature in the hood rises or the amount of smoke increases, the supply and exhaust fans will ramp-up their speed to exhaust the fumes

quickly and reduce the temperature in the hood. They will ramp down when the temperature or the smoke in the hood decrease.

2- Energy Management System

The existing HVAC control system at West School consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, lack flexibility and accuracy. A set of manual clocks with pneumatic sensors are complex to operate and the custodians get confused on how the system works. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and automatically reset the heating system (Steam boilers and main steam valves) based on outdoor air temperature. They will also have a better monitoring system which will reduce the run hours on the boilers and the heating systems.

3- Variable Frequency Drives on Gym AHUs

The Gymnasium is ventilated by two 3 HP air handling units with steam heating coils. The AHUs are constant volume. We propose to add a VFD on each AHU to allow the fan motors to vary based on the temperature in the space.

4- Steam Traps Replacement

The building is heated with steam. There is at least one steam trap on each heating unit and one steam trap on the distribution lines. They are not regularly serviced. The practice is to replace them at the same time once in five years. They have not been replaced for a long period. We propose to replace them at the same time, with an accuracy of reducing the energy consumption by a minimum of 3%.

HELEN H. HANSON ELEMENTARY:

1- Energy Management System

The existing HVAC control system at Hanson Elementary School consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, old and inaccurate. During the heating season, when the outdoor temperature is 30 degrees F or below, the heating is overridden and all the HVAC units (Pumps, boilers, UVs) run constantly, including during the unoccupied hours. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and reset heating hot water based on outdoor air temperature. They will also have a better monitoring system which will reduce the run hours on the boilers and the heating systems.

2- Burners Electronic Control

The existing burners have mechanical cam controls on boilers which were installed in 1986. We propose to install electronic controls on the burners to adjust their operation pattern based on the thermal load.

3- Variable Frequency Drives on Hot Water Pumps

There are four heating hot water pumps serving four different zones of the school. Two pumps are <1.5 HP and two pumps are 3 HP each. We propose to add VFDs on these two large pumps to vary the hot water flow in the spaces they serve based on the thermal load demand.

4- Demand Control Ventilation

There are approximately 24 unit ventilators serving classrooms. We propose to add CO2 sensors on each unit ventilator and modulate the fresh air introduced into the classrooms based on the occupancy of the space. This will reduce the amount of cold air needed to be heated during the heating season while saving energy at the same time.

SOUTH ELEMENTARY SCHOOL

1- Burners Control

The existing burners have mechanical cam controls on boilers which were installed in 1986. We propose to install electronic controls on the burners to adjust their operation pattern based on the thermal load.

2- VFD on Hot Water Pumps

Two heating hot water pumps are used for circulating heating hot water. Their motors have no VFD. Each motor is 3 HP size. We propose to add two 3 HP VFD on each of the two heating hot water pump motors and modulate their speed based on the thermal loads of the spaces they serve.

3- Energy Management System

The existing HVAC control system at South Elementary School consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, old and inaccurate. During the heating season, when the outdoor temperature is 30 degrees F or below, the heating is overridden and all the HVAC units (Pumps, boilers, UVs, fan motors) run constantly, including during the unoccupied hours, until the outdoor air temperature is above 30 degrees F again. This type of building operation is expensive and can be improved without freezing hot water pipes, as feared by the building operators. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and reset heating hot water based on outdoor air temperature. They will also have a better monitoring system which will reduce the run hours on the boilers and the heating systems

4- Programmable Thermostats

The Teachers Room, the Conference room and the library have manual thermostats controlling the temperature in the space. We propose to replace them and install programmable thermostats to allow temperature setback at night and on weekends when the spaces are not occupied.

E.A. JONES ELEMENTARY SCHOOL

1- Pipe Insulation

There are 25 feet 4" steam pipes on boiler #2 which are bare and uninsulated, resulting in significant heat losses. We propose to insulate these bare pipes with appropriate fiber glass to reduce heat losses and improve the boilers efficiency.

2- Energy Management System

The existing HVAC control system at Jones Elementary School consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, inaccurate and complicated to operate. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide scheduling of HVAC equipment operation, and automatically reset the heating system (Steam boilers and main steam valves) based on outdoor air temperature. They will also have a better monitoring system which will reduce the run hours on the boilers and the heating systems.

3- Burners Electronic Control

The existing burners for the steam boilers have mechanical cam controls which were installed at least a few decades ago. We propose to install electronic controls on the burners to adjust their operation pattern based on the thermal load.

4- Steam Traps Replacement

The building is heated with steam. There is at least one steam trap on each heating unit and one steam trap on the distribution lines. They are not regularly serviced. The practice is to replace them at the same time once in five years. They have not been replaced for a long period. We propose to replace them at the same time, with an accuracy of reducing the energy consumption by a minimum of 3%.

HIGH SCHOOL

1- Install VFDs on Air Handling units

AHUs which are used to ventilate, heat and cool various area of the high school are constant volume. They are located in the gymnasium, cafeteria, locker rooms and some classrooms and large spaces. We propose to install variable frequency drives on each of the AHU fan motor to modulate the speed of the fan motor based on the temperature in the space to save electric energy.

2- DDC Overlay on Pneumatic controls

The existing HVAC control system at the high school consists of a combination of old pneumatic controls timers for equipment operation and scheduling. These controls are antiquated, inaccurate and often very complex to operate. We propose to add a DDC control system as an overlay to the existing pneumatic system. The DDC System will allow the building operators to perform a building wide

recalibration of the sensors and pneumatic devices and be able to view their performance on a screen at the same time.

3- HVAC Scheduling – Start/ Stop

This measure consists of upgrading the existing pneumatic controls to allow a strict scheduling of HVAC equipment. Currently, scheduling of large equipment is performed individually by mechanical timers, while other HVAC equipment (EF, UVs) are not scheduled. A DDC control system (Front end) combined to overlay on pneumatic controls will allow to turn off HVAC equipment based on a schedule set by the building operators.

4- Heating Hot Water Temperature Reset

This measure consists of varying the heating hot water temperature based on outdoor air temperature, rather than maintaining a constant water temperature for the heating hot water. This measure saves a significant amount of energy when the temperature outside is above freezing.

5- Main Steam Valve Control

One side of the high school is heated with steam. We propose to control the steam flow from the boilers based on outdoor air temperature by matching the space temperature needs with the lengths the main steam valve is open/closed during unoccupied hours when no AHUs with steam coils are in use. This measure allows to reduce the load on the steam boilers, especially during mild weather to avoid space overheating.

6- Pipes and Valves Insulation

The building has many areas where the insulation of the heating pipes has deteriorating, exposing bare pipes. In addition, big size steam valves radiate a lot of heat in the mechanical rooms. This measure will consist of insulating heating hot water pipes in the mechanical rooms where the insulation has deteriorated, insulation of steam pipes with fiber glass insulation material, and putting insulation blankets around large steam valves.

7- Kitchen Hood Control

The kitchen ventilation is achieved by one make up air unit which supplies 100% outside air to the kitchen. This air is then exhausted through the hood to insure no fume is returned into the facility. The make-up air unit and the exhaust fan are constant volume. The air supplied to the kitchen needs to be conditioned (heated depending on the season and set points). The kitchen is open in the morning and closes late in the evening. We propose to add controls and variable frequency drives on the air make up air fan motor and on the exhaust fans motor to modulate based on the smoke and the temperature inside the hood. In addition, a schedule to shut off the make-up air unit and the exhaust fan when the kitchen closes will be put in place to save energy. When the temperature in the hood rises or the amount of smoke increases, the supply and exhaust fans will ramp-up their speed to exhaust the fumes quickly and reduce the temperature in the hood. They will ramp down when the temperature or the smoke in the hood decrease.

8- Boiler Burners Control

The high school heating system consists of four 6,300 MBH boilers located in two mechanical rooms. There are two boilers in each mechanical room. One boiler in each mechanical room is used to handle the thermal load during the heating season, while the other one is in standby mode.

The boilers burners are mechanically controlled. We propose to retrofit them and have them electronically controlled. At the same time, we propose to track the excessive amount of air in the stack, add VFDs on the boiler supply air motors and modulate the speed of the motors based on the O₂ level in the exhaust. This strategy maintains an almost constant O₂ level in the stack while reducing the amount of energy needed to heat cold air brought into the combustion chamber of the boiler.

9- Steam Traps Replacement

One side of the building is heated with steam. There is at least one steam trap on each heating unit and one steam trap on each distribution line. They are not regularly serviced. The last time these traps were replaced was almost ten years ago. The practice is to replace them at the same time once every five to seven years. We propose to replace all of them at the same time, with an accuracy of reducing the energy consumption by a minimum of 3%.

STOUGHTON ENERGY AUDITS

Building Name and/or Location	Projected Annual Electricity Savings (kWh)	Projected Annual Gas Savings (Therms)	Total Annual Electricity Usage without Street/Traffic Lights or High School (kWh)	Total Annual Gas Usage without High School (Therms)	Projected Annual Propane Savings (Gallons)	Projected Annual Cost Savings	ESTIMATED Total Project Cost	Estimated Incentives	ESTIMATED Total Cost After incentives	Estimated Payback After Incentives (years)
TOTALS	907,108	105,247	5,091,868	512,972	40	265,622	2,690,751	329,239	2,361,512	8.9
CEDAR HILL GOLF COURSE: 1137 Park Street, Stoughton, MA 02072	55,884									
Lighting	3,985					\$655	\$6,740	\$1,920	\$4,820	7.4
Programmable Thermostat - Men's Bathroom	1,995					\$328	\$1,200	\$499	\$701	2.1
Low-Flow Sink Aerators		83				\$91	\$700	\$83	\$617	6.8
Kitchen Hood Control	3,219	1,641				\$2,334	\$32,000	\$2,446	\$29,554	12.7
Demand Control Ventilation	1,515	420				\$711	\$7,800	\$799	\$7,001	9.8
VFD on RTU	5,366					\$882	\$11,000	\$1,342	\$9,659	10.9
COUNCIL ON AGING/SENIOR CENTER: 110 Rockland Street, Stoughton, MA 02072	68,640									
Lighting	12,825					\$2,108	\$27,591	\$4,165	\$23,426	11.1
CLAPP LIBRARY/HISTORICAL SOCIETY: 6 Park Street, Stoughton, MA 02072	8,256									
Boiler Replacement		848				\$933	\$48,000	\$4,000	\$44,000	47.2
Programmable Thermostats		680				\$748	\$3,300	\$680	\$2,620	3.5
DPW Truck Maint. Garage, Account Number 7546051019: 950 Central Street, Stoughton, MA 02072	100,488									
Lighting	42,256					\$6,947	\$68,840	\$12,765	\$56,075	8.1
Maintenance Garage& Mechanical Bay Programmable Thermostats	10,660	4,199				\$6,371	\$19,700	\$6,864	\$12,836	2.0
DPW Office and Storage Garages, Account Number 8793859013: 950 Central Street, Stoughton, MA 02072	41,148									
Lighting	19,221					\$3,160	\$41,510	\$10,600	\$30,910	9.8
Main Entrance FCU Programmable Thermostat		98				\$108	\$700	\$98	\$602	5.6
FIRE STATION 2: 1550 Central Street, Stoughton, MA 02072	110,496									
Lighting	22,402					\$3,683	\$44,063	\$4,200	\$39,863	10.8
Low-Flow Sink Aerators		178				\$196	\$800	\$178	\$622	3.2
Dorm Programmable Thermostats - Heating		141				\$155	\$1,200	\$141	\$1,059	6.8
Dorm Programmable Thermostats - Cooling	2,236					\$368	\$3,100	\$559	\$2,541	6.9
Garage Bay - Programmable Thermostats		2,122				\$2,334	\$5,400	\$2,122	\$3,278	1.4
FIRE STATION 1: 30 Freeman Street, Stoughton, MA 02072	104,172									
Lighting	14,356					\$2,360	\$18,668	\$840	\$17,828	7.6
Replace Boiler		1,826				\$2,009	\$97,500	\$8,000	\$89,500	44.6
Add Centralized Cooling	9,274					\$1,525	\$45,000	\$2,319	\$42,682	28.0
Main Common Area Programmable Thermostats		354				\$389	\$2,100	\$354	\$1,746	4.5
Garage Bay - Programmable Thermostats		5,658				\$6,224	\$14,700	\$5,658	\$9,042	1.5
LIBRARY: 84 Park Street, Stoughton, MA 02072	191,940									
Lighting	46,175					\$7,591	\$98,629	\$12,205	\$86,424	11.4
Boiler Replacement		1,118				\$1,230	\$92,000	\$1,118	\$90,882	73.9
Weatherization	220	189				\$244	\$1,200	\$244	\$956	3.9
DCV	3,349	383				\$972	\$11,000	\$1,220	\$9,780	10.1
VFDs on Chilled Water Pumps	5,981					\$983	\$12,000	\$1,495	\$10,505	10.7

VFDs on Hot Water Pumps	3,198					\$526	\$12,000	\$800	\$11,201	21.3
Chiller Compressors Replacement	12,000					\$1,973	\$63,000	\$3,000	\$60,000	30.4
VFDs on AHUs	16,678					\$2,742	\$27,000	\$4,170	\$22,831	8.3
PRATTS COURT WATER TREATMENT: Pratts Court, Stoughton, MA 02072	133,320									
Lighting	12,597					\$2,071	\$23,209	\$1,640	\$21,569	10.4
Programmable Thermostats		328			40	\$453	\$4,900	\$328	\$4,572	10.1
VFDs on 60 HP and 15 HP Pump Motor	47,772					\$7,854	\$48,000	\$11,700	\$36,300	4.6
PLC Controls Upgrade	7,000					\$1,151	\$11,000	\$1,750	\$9,250	8.0
PUMP STATION #1: 1740 Central Street, Stoughton, MA 02072										
VFD on 100 HP Pump Motor	68,838					\$11,317	\$55,000	\$12,500	\$42,500	3.8
PUMP STATION #3: King Street, Stoughton, MA 02072	78,000									
PLC Controls on three 40 HP VFDs	18,895					\$3,106	\$13,000	\$4,724	\$8,276	2.7
PUMP STATION #5: Plain Street, Stoughton, MA 02072	196,188									
VFD on 60 HP Pump Motor	67,831					\$11,151	\$45,300	\$8,250	\$37,050	3.3
GODDARD WELL: 909 Summer Street, Stoughton, MA 02072	80,292									
VFD on 20 HP Pump Motor	20,871					\$3,431	\$19,000	\$3,900	\$15,100	4.4
THREE SEWER PUMPS - Stoughton, MA 02072										
VFD on three 25 HP pump motors	34,959					\$5,747	\$37,500	\$13,950	\$23,550	4.1
POLICE STATION: 26 Rose Street, Stoughton, MA 02072	221,940									
Low-Flow Sink Aerators		208				\$229	\$600	\$208	\$392	1.7
Cooling System Upgrade	26,000					\$4,274	\$72,000		\$72,000	16.8
Demand Control Ventilation	6,612	1,259				\$2,472	\$18,000	\$2,912	\$15,088	6.1
ROBERT O'DONNELL MIDDLE SCHOOL: 211 Cushing Street, Stoughton, MA 02072	527,244 95,598									
Weatherization	401	453				\$564	\$3,800	\$553	\$3,247	5.8
New Hot Water Heater (DHW)		1,995				\$2,195	\$37,000	\$1,995	\$35,005	16.0
Kitchen Hood Controls	4,507	1,597				\$2,498	\$35,000	\$2,724	\$32,276	12.9
VFDs on HW Pumps	7,987					\$1,313	\$18,000	\$2,000	\$16,000	12.2
EMS	3,491	787				\$1,440	\$27,000	\$1,660	\$25,340	17.6
Demand Control Ventilation		2,520				\$2,772	\$52,000	\$2,520	\$49,480	17.8
GIBBONS ELEMENTARY: 235 Morton Street, Stoughton, MA 02072	211,488 35,884									
Burner Electronic Control		1,140				\$1,254	\$16,000	\$1,140	\$14,860	11.9
VFD on gym AHUs and Mech Room	10,569					\$1,738	\$27,000	\$3,000	\$24,000	13.8
EMS	5,479	5,616				\$7,078	\$69,000	\$6,986	\$62,014	8.8
Demand Control Ventilation		1,057				\$1,163	\$28,000	\$1,057	\$26,943	23.2
JOSEPH R. DAWE ELEMENTARY: 131 Pine Street, Stoughton, MA 02072	237,132 47,759									
EMS		1,064				\$1,801	\$22,500	\$1,064	\$21,436	11.9
Burners Automatic Control		655				\$721	\$9,800	\$655	\$9,145	12.7
Programmable Thermostats	16,885					\$2,776	\$7,200	\$4,221	\$2,979	1.1
Kitchen Equipment Conversion	14,400	-517				\$1,799	\$28,000	\$3,600	\$24,400	13.6
WEST ELEMENTARY: 1322 Central Street, Stoughton, MA 02072	240,828 63,211									
Kitchen Hood Control	7,404	798				\$2,095	\$35,000	\$2,649	\$32,351	15.4
EMS	3,162	9,809				\$11,310	\$97,000	\$10,599	\$86,401	7.6
Add VFD on the Gym AHU (2 -3 hp VFDs)	10,285					\$1,691	\$20,000	\$2,000	\$18,000	10.6

Steam Traps Replacement		1,880				\$2,068	\$26,000	\$1,880	\$24,120	11.7
HELEN H. HANSON ELEMENTARY: 1800 Central Street, Stoughton, MA 02072										
	162,624		37,850							
EMS	7,889	6,619				\$8,578	\$87,000	\$8,591	\$78,409	9.1
Burner Electronic Control		1,700				\$1,870	\$20,000	\$1,700	\$18,300	9.8
VFDs on HW Pumps	7,987					\$1,313	\$18,000	\$2,000	\$16,000	12.2
Demand Control Ventilation		861				\$947	\$22,000	\$861	\$21,139	22.3
SOUTH ELEMENTARY SCHOOL: 171 Ash Street, Stoughton, MA 02072										
	153,612		32,965							
Burner Electronic Control		1,100				\$1,210	\$20,000	\$1,100	\$18,900	15.6
VFDs on two Hot Water Pumps	12,138					\$1,995	\$18,000	\$2,000	\$16,000	8.0
EMS	10,744	5,994				\$8,360	\$97,000	\$8,680	\$88,320	10.6
Programmable Thermostats	433	292				\$392	\$3,600	\$400	\$3,200	8.2
E.A. JONES ELEMENTARY: 137 Walnut Street, Stoughton, MA 02072										
	147,180		42,409							
Boiler 2 Pipe Insulation		293				\$322	\$2,600	\$293	\$2,308	7.2
EMS	2,161	6,596				\$7,611	\$83,000	\$7,136	\$75,864	10.0
Burner Electronic Control		585				\$644	\$20,000	\$585	\$19,415	30.2
Steam Traps Replacement		1,170				\$1,287	\$22,000	\$1,170	\$20,830	16.2
HIGH SCHOOL: 234 Pearl Street, MA 02072										
VFDs on Fan Motors	14,700					\$2,417	\$24,000	\$3,675	\$20,325	8.4
DDC Overlay on Pneumatic Controls	36,000	2,000				\$8,118	\$98,000	\$11,000	\$87,000	10.7
Demand Control Ventilation		4,600				\$5,060	\$78,000	\$4,600	\$73,400	14.5
HVAC Start/Stop Scheduling	165,000	4,200				\$31,746	\$99,000	\$45,450	\$53,550	1.7
Heating HW temperature Reset		2,000				\$2,200	\$34,000	\$2,000	\$32,000	14.5
Steam Main Valve Control		6,100				\$6,710	\$74,000	\$6,100	\$67,900	10.1
Pipes Insulation		1,700				\$1,870	\$7,300	\$1,700	\$5,600	3.0
Kitchen Hood Control	9,000	1,150				\$2,745	\$29,000	\$3,400	\$25,600	9.3
Boiler Burners Controls	8,200	5,600				\$7,508	\$87,000	\$7,650	\$79,350	10.6
Steam Traps Replacement		2,100				\$2,310	\$23,000	\$2,100	\$20,900	9.0

VI. Appendix B: Town of Stoughton Streetlight Retrofit Proposal – Spec Lines

Project Name: _____

Stoughton Green Cobra LED Street Light Conversion ROI NGRID TARIFF demo

Client: _____

Town of Stoughton

Prepared By: _____ Date: _____



Ben 23-Mar-15

Note: These are estimated savings only. Annual and monthly savings are based on a number of variables and assumptions that could change over time. The actual savings derived for the project may be higher or lower. Spec-lines does not imply a warranty of performance or savings as calculated and shown within this program and document.

System Energy Cost Summary							
	Total Initial Cost	Total Number of Fixtures	Total System kW	Annual kWh	Cost of Energy per kWh	kWh Inflation Rate (%/yr)	First Year Energy Cost
Proposed Spec-lines LED	\$362,511	2,123	78.26	326,767	\$0.140	2.00%	\$45,747
Existing HID Fixtures	N/A	2,123	211.92	884,898	\$0.140	2.00%	\$123,886

Payback Analysis: Energy Savings			
First Year Energy Savings	Cost of Waiting (monthly)	Simple Payback (years)	IRR (%)
\$78,138	\$6,512	4.64	23%

Sample Financing				
	Project Cost	Interest Rate	Payment (\$/yr)	Total Project Cost After Repayment
No Financing	\$362,511	--	--	\$362,511
5 year Term	\$362,511	3.00%	\$79,156	\$395,779
10 year Term	\$362,511	3.00%	\$42,497	\$424,973



ENERGY USE REDUCED BY **63%**

10 YEAR SAVINGS **\$855,594**

RETURN ON INVESTMENT **4 years + 7 months**

By converting to LED, this project will save 558,132 kWh per year.



This savings is equal to the emissions produced by 81 cars a year!



Or the amount of carbon sequestered by 315 acres of U.S. forests in one year!



This project would remove 848,463 lbs of CO2 emissions!



Project Name:

Stoughton Green Cobra LED Street Light Conversion ROI NGRID TARIFF demo

Client:

Town of Stoughton

kWh Inflation Rate (%/yr): 2.00%

Daily Operating Hours: 11.44

Note: These are estimated savings only. Annual and monthly savings are based on a number of variables and assumptions that could change over time. The actual savings derived for the project may be higher or lower. Spec-lines does not imply a warranty of performance or savings as calculated and shown within this program and document.

	New Fixture	No. of Fixtures	Annual kWh	Cost per kWh	Year 1 Energy Costs	Rebate	per Fixture Costs	per Fixture Installation Costs	Total Retrofit Costs	Net Project Costs
A	1-20G-350	1,540	152,723	\$0.140	\$21,381	\$91,634	\$133	\$100	\$358,820	\$267,186
B	1-20G-350	252	24,991	\$0.140	\$3,499	\$14,995	\$133	\$100	\$58,716	\$43,721
C	1-20G-580	102	10,115	\$0.140	\$1,416	\$12,138	\$133	\$100	\$23,766	\$11,628
D	1-30F-700	43	12,793	\$0.140	\$1,791	\$5,117	\$171	\$100	\$11,653	\$6,536
E	1-30F-700	3	893	\$0.140	\$125	\$536	\$171	\$100	\$813	\$277
F	2-40F-1000	96	47,602	\$0.140	\$6,664	\$17,137	\$206	\$100	\$29,376	\$12,239
G	2-100F-700	87	77,651	\$0.140	\$10,871	\$25,884	\$438	\$100	\$46,806	\$20,922
H	--	--	--	--	--	--	--	--	--	--
I	--	--	--	--	--	--	--	--	--	--
J	--	--	--	--	--	--	--	--	--	--
TOTAL		2,123	326,767		\$45,747	\$167,439			\$529,950	\$362,511

Year	Payment	NEW LED SYSTEM COSTS AND INCENTIVES				EXISTING SYSTEM COSTS		SAVINGS BY SWITCHING TO LED			
		Total Rebate	New Energy Costs	New Annual Costs	New Cumulative Costs	Existing Energy Costs	Existing Cumulative Energy Costs	Energy Savings (Existing - New)	Net Annual Savings Costs	or	Cumulative Savings
1	\$42,497	\$167,439	\$45,747	(\$79,195)	(\$79,195)	\$123,886	\$123,886	\$78,138	\$203,081		\$203,081
2	\$42,497		\$46,662	\$89,160	\$9,965	\$126,363	\$250,249	\$79,701	\$37,204		\$240,284
3	\$42,497		\$47,596	\$90,093	\$100,058	\$128,891	\$379,140	\$81,295	\$38,798		\$279,082
4	\$42,497		\$48,547	\$91,045	\$191,102	\$131,469	\$510,609	\$82,921	\$40,424		\$319,506
5	\$42,497		\$49,518	\$92,016	\$283,118	\$134,098	\$644,707	\$84,580	\$42,082		\$361,588
6	\$42,497		\$50,509	\$93,006	\$376,124	\$136,780	\$781,486	\$86,271	\$43,774		\$405,362
7	\$42,497		\$51,519	\$94,016	\$470,140	\$139,516	\$921,002	\$87,997	\$45,499		\$450,862
8	\$42,497		\$52,549	\$95,047	\$565,187	\$142,306	\$1,063,308	\$89,756	\$47,259		\$498,121
9	\$42,497		\$53,600	\$96,098	\$661,285	\$145,152	\$1,208,460	\$91,552	\$49,054		\$547,175
10	\$42,497		\$54,672	\$97,170	\$758,454	\$148,055	\$1,356,515	\$93,383	\$50,885		\$598,060
11	\$0		\$55,766	\$55,766	\$814,220	\$151,016	\$1,507,531	\$95,250	\$95,250		\$693,311
12	\$0		\$56,881	\$56,881	\$871,101	\$154,036	\$1,661,567	\$97,155	\$97,155		\$790,466
13	\$0		\$58,019	\$58,019	\$929,120	\$157,117	\$1,818,684	\$99,098	\$99,098		\$889,564
14	\$0		\$59,179	\$59,179	\$988,299	\$160,259	\$1,978,944	\$101,080	\$101,080		\$990,645
15	\$0		\$60,363	\$60,363	\$1,048,661	\$163,465	\$2,142,408	\$103,102	\$103,102		\$1,093,747
16	\$0		\$61,570	\$61,570	\$1,110,231	\$166,734	\$2,309,142	\$105,164	\$105,164		\$1,198,911
17	\$0		\$62,801	\$62,801	\$1,173,033	\$170,069	\$2,479,211	\$107,267	\$107,267		\$1,306,178
18	\$0		\$64,057	\$64,057	\$1,237,090	\$173,470	\$2,652,681	\$109,413	\$109,413		\$1,415,591
19	\$0		\$65,338	\$65,338	\$1,302,429	\$176,939	\$2,829,620	\$111,601	\$111,601		\$1,527,192
20	\$0		\$66,645	\$66,645	\$1,369,074	\$180,478	\$3,010,098	\$113,833	\$113,833		\$1,641,025
TOTAL	\$424,973		\$1,111,540	\$1,369,074		\$3,010,098		\$1,898,558	\$1,641,025		

VII. Appendix C: MMBTU Conversion Chart – DOER

MMBTU Conversion Chart⁷

Fuel Energy Content of Common Fossil Fuels per DOE/EIA

BTU Content of Common Energy Units – (1 million BTU equals 1 MMBTU)

- 1 kilowatt hour of electricity = 0.003412 MMBTU
- 1 therm = 0.1 MMBTU
- 1 ccf (100 cubic foot) of natural gas = 0.1028 MMBTU (based on U.S. consumption, 2007)
- 1 gallon of heating oil = 0.139 MMBTU
- 1 gallon of propane = 0.091 MMBTU
- 1 cord of wood = 20 MMBTU
- 1 gallon of gasoline = 0.124 MMBTU (based on U.S. consumption, 2007)
- 1 gallon of E100 ethanol = 0.084 MMBTU
- 1 gallon of E85 ethanol = 0.095 MMBTU
- 1 gallon of diesel fuel = 0.139 MMBTU
- 1 gallon of B100 biodiesel = 0.129 MMBTU
- 1 gallon of B20 biodiesel = 0.136 MMBTU⁸
- 1 gallon of B10 biodiesel = 0.137 MMBTU⁷
- 1 gallon of B5 biodiesel = 0.138 MMBTU⁷
- 1 barrel of residual fuel oil = 6.287 MMBTU

⁷ If a conversion factor for a fuel you use is not provided, please contact DOER.

⁸ Calculated Values from those of diesel and B100 biodiesel