




Industrial Technologies Program

GOALS

- ***Energy savings***
- Environmental quality
- Yield improvement/
Resource conservation
- Economic viability
- Energy security

Targeting the largest
opportunity to save energy
in the United States

2001 Energy Use






Industry: Critical to National Energy Policy

- 1/3 of U.S. **energy consumption**
- Accounts for more than 40% of U.S. **natural gas** demand
- 28% of U.S. electricity demand
- Approximately 30% of U.S **greenhouse gas** emissions
- Energy is key to **economic growth** in domestic manufacturing

2004 Energy Use*



*Includes electricity losses

Source: DOE/EIA Monthly Energy Review 2004 (preliminary)



Industrial Technologies Program

MISSION

Improve the energy intensity of U.S. industry through coordinated research and development, validation, and dissemination of energy efficiency technologies & practices.

Partner with industry and other stakeholders to:

- Increase energy savings
- Reduce environmental impacts
- Improve process yield/conserves resources
- Reduce reliance on foreign oil
- Increase use of renewable energy
- Improve competitiveness and quality of life



Delivering Technology Solutions

Collaborative R&D




- Energy-intensive industries (IOF)
- Crosscutting Technologies
- Grand Challenges



Partnerships

Technology Delivery



- Assessments
- Training & Tools
- Emerging Technologies
- Demonstrations



EERE Allied Partners:



- Enrich existing services to industrial plants by delivering EERE tools, training, information, technologies, and other opportunities for energy savings.
- Expand industry's access to EERE products and services.
- Work with EERE to develop case studies, training seminars, software tools, conference sessions, etc.





DOE Resources Available for Industry


- Assessments
- Software Tools
- Training
- Qualified Specialists
- Information
- Information Center
- Web Sites





Energy Savings Assessments

- By the end of 2007 DOE will have conducted 450 system assessments of large facilities, focusing on steam, process heating, compressed air, pump, and fan systems.
- Assessments done by teams composed of DOE Qualified Energy Experts and plant personnel
- Plant personnel and affiliates will be trained on DOE efficient tools
- Energy Savings Assessment Report identifies potential energy and cost savings and possible next steps



U.S. Manufacturing
Energy Use by Type
of System (%)

Note: Does not include off-site losses



“Easy Ways to Save Energy” Campaign

- A response to hurricanes Katrina and Rita and disruption in energy supplies
- DOE/Energy Efficiency & Renewable Energy (EERE) has created four initiatives
 1. Energy Hog campaign – Public Service Announcements
 2. Energy Savers tips to help homeowners save energy
 3. Federal Energy Management Program (FEMP) energy saving teams
 4. Industrial Energy Technologies (ITP) **“Save Energy Now”**





Industrial Assessment Centers

Qualification Criteria

- Annual sales under \$100 million
- 500 or less employees at plant
- No designated energy manager
- Energy bill less than \$2 M/yr and greater than \$100K/yr
- Plant located 150 miles or less from IAC school




Contact your nearest IAC university to request an assessment.

Visit: <http://iac.rutgers.edu/database/>



Replicating Assessment Savings





Tools Available on Our Web Site

- **Motor Master +** Assists in energy-efficient motor selection and management. (International)
- **Pumping System Assessment Tool** Assesses the efficiency of pumping system operations.
- **Fan System Assessment Tool** quantifies potential benefits of a more optimally configured fan system
- **Chilled Water System Assessment Tool** Assesses the efficiency of a chilled water system.
- **Air Master+** Provides comprehensive information on assessing compressed air systems.
- **ASDMaster** Determines economic feasibility of an ASD application.





Tools Available on Our Web Site

- **Steam System Scoping Tool**
Profiles and grades large steam system operations/management.
- **Steam System Assessment Tool**
Assesses potential benefits of specific steam-system improvements.
- **3EPlus Insulation Assessment Tool**
Calculates most economical thickness of insulation for a variety of operating conditions.
- **Process Heating Assessment and Survey Tool**
Assesses energy use in furnaces/ performance improvements
- **NOx and Energy Assessment Tool (NxEAT)**
analyzes NOx emissions and energy efficiency improvements
- **Plant Energy Profiler**
profiles plant energy supply along consumption streams and identifies energy savings opportunities



Training Opportunities for Software Tools


- Awareness Workshops (usually 1-2 hours)
- Webcasts (1-2 hours)
- End-user training (1-2 days)
- Qualified specialist training (2-3 days)
 - Potential resource for plant personnel



See
www.eere.energy.gov/industry
for details



Information



- Tip sheets, case studies, brochures, technical briefs etc.
- *Energy Matters* newsletter
- Industrial Technologies Monthly e-bulletin
- Software tools and training
- Web sites

<http://www.eere.energy.gov/industrybestpractices/training.html>



U.S. Department of Energy
Energy Efficiency and Renewable Energy

Energy Efficiency and Renewable Energy Information Center

On-call team of professional engineers, scientists, research librarians, energy specialists, and communications information staff

Voice: 877-337-3463

Fax: 360-236-2023


Email: eeecsc@ee.doe.gov



Website: www.eere.energy.gov/informationcenter



Motor Master Software



**Will Help You
With Motor
Purchasing
And Overall Motor
Systems
Management**



What is a Motor System?







The Electric Motor System

Three-Phase
Input Power

Process Mechanical and Electrical Feedback



Motor/Drive Subsystem Mechanical Subsystem





MotorMaster+



- Runs on any Windows-based platform
- Requires at least 8 MB of memory and a hard disk with at least 10 MB of free disk space
- Easy to learn and use



Motor Comparison: Replace Oversized Motor

Motor Comparison			
File Savings Help			
<input type="radio"/> New <input type="radio"/> Rewind <input checked="" type="radio"/> Replace Existing		Savings ? Exit	
Utility Portland General E	Existing Description: Ref Compressor #1 Manufacturer: Size/Speed: 60 hp 1800 RPM Enclosure/Voltage: ODP 440 Volts Special Feature: All	Energy-Efficient E-PLUS 3 MagneTek 50 hp 1800 RPM ODP 440 Volts All	
Rate Schedule General Service	Hours use/yr: 6240 Load (%): 68.7 Efficiency (%): 91.5 Full load RPM: 1760	6240 82.3 95.1 1765	<input type="button" value="Inventory"/> <input type="button" value="Catalog"/> <input type="button" value="Copy Values"/>
Facility Concentrated Juice	Old Motor Effic Loss: Dealer discount (%): Purchase Price (\$): Installation Cost (\$): Motor Rebate (\$): Peak Months: 12	<input checked="" type="checkbox"/> Centrifugal load 25.0 1899 115 375 12	
Energy price (\$/kWh): 0.03933 Demand charge (\$/kW): 3.67 Utility rebate program in effect			




Pumping System Assessment Tool

- Assesses the efficiency of pumping system operations.





Big picture perspective of energy flow for pumping systems





An introduction to the Pumping System Assessment Tool (PSAT)

- Goal: to assist pump users in identifying pumping systems that are the most likely candidates for energy and cost savings
- Requires field measurements or estimates of flow rate, pressure, and motor power or current
- Uses pump and motor performance data from Hydraulic Institute standard ANSI/HI-1.3 and MotorMaster+ to estimate existing, achievable performance




U.S. Department of Energy
Energy Efficiency and Renewable Energy

Demineralized and tower water pumping station for the Fusion Energy complex





As found conditions: One chiller in operation, but
3 or 4 tower pumps running.





Applying the PSAT tool to the measured conditions showed significant potential savings

Pump, motor, system information:

Pump style: API double section

Pump nameplate speed, rpm: 1785

Fluid viscosity (cS): 1.0 Specific gravity: 1.00

Number of stages: 1

Motor size selection: Custom (selected) Std nameplate hp: 350

Motor nameplate speed, rpm: 1785

Existing motor class: Standard efficiency

Nominal motor voltage, volts: 2300

Operating parameters:

Operating fraction: 1.000

Electricity cost, cents/kWh: 5.40

Measured or required conditions:

Measured flow rate: 1200 gpm

Measured head: 367.0 ft

Load estimation method: Power

Measured power: 154.0 kW

Measured bus voltage: 2370

Input basis:

Measured (selected) Required

STOP

	Existing pump, motor	Existing pump, EE motor	Optimal pump, EE motor
Pump efficiency, %	57.4	57.4	72.5
Motor rated hp	350	350	200
Shaft power, hp	193.6	193.6	138.6
Motor efficiency, %	93.8	95.3	95.6
Motor power factor, %	79.6	79.7	82.5
Motor current, amps	47.1	46.3	31.9
Electric power, kW	154.0	151.5	108.2
Annual energy, MWhr	1349.0	1327.3	947.4
Annual cost, \$1,000	72.8	71.7	51.2
Annual savings, \$1,000	0.0	1.2	21.6

Size margin (%) for optimal pump motor: 25

Optimization rating

70.2

Click for background information

Potential annual savings ~ \$22K

Log current data Retrieve Log data Create new or append existing summary file -->

Existing pump, motor: 154.0 kW

Facility: Y-12, Fusion System: Demineralized water Date: January 26, 1999

Application: Low pressure pump J104 Evaluator: Don Casada

Notes: Current and voltage monitored from secondary of CT's, PT's; head from suction, discharge test gauges. Flow rate estimated from head curve. (Data acquired following J102 motor replacement with 6-pole motor)



Using the required head estimate instead of the actual operating head could yield much greater savings

Pump, motor, system information:

Pump style: API double section

Pump nameplate speed, rpm: 1785

Fluid viscosity (cS): 1.0 Specific gravity: 1.00

Number of stages: 1

Motor size selection: Custom Std nameplate hp: 350

Motor nameplate speed, rpm: 1785

Existing motor class: Standard efficiency

Nominal motor voltage, volts: 2300

Operating parameters:

Operating fraction: 1.000

Electricity cost, cents/kwhr: 5.40

Measured or required conditions:

Required flow rate: 1200 gpm

Required head: 140.0 ft

Load estimation method: Power

Input basis: Measured Measured power: 154.0 kWe

Measured bus voltage: 2370

STOP

	Existing pump, motor	Existing pump, EE motor	Optimal pump, EE motor
Pump efficiency, %	21.9	21.9	79.3
Motor rated hp	350	350	75
Shaft power, hp	193.6	193.6	52.9
Motor efficiency, %	93.8	95.3	94.7
Motor power factor, %	79.6	79.7	81.2
Motor current, amps	47.1	46.3	12.5
Electric power, kWe	154.0	151.5	41.7
Annual energy, MWhr	1349.0	1327.3	365.0
Annual cost, \$1,000	72.8	71.7	19.7
Annual savings, \$1,000	0.0	1.2	

Size margin (%) for optimal pump motor: 25

Optimization rating

27.1

Click for background information

Potential annual savings ~ \$53K

Log current data Retrieve Log data Create new or append existing summary file -->

Facility: Y-12, Fusion System: Demineralized water Date: January 26, 1999

Application: Low pressure pump J104 Evaluator: Don Casada

Notes: Current and voltage monitored from secondary of CT's, PT's. Flow rate estimated from head curve. (Data acquired following J102 motor replacement with 6-pole motor). The head and flow rate represent estimate requirements (head is conservatively high).




Chilled Water System Assessment Tool

- Assesses the efficiency of a chilled water system.





A Chilled Water System





U.S. Department of Energy
Energy Efficiency and Renewable Energy

Air Master+: A Compressed Air Systems Assessment Tool



AirMaster

Air Master can be used to baseline a compressed air system and then evaluate the energy savings from seven EEM's:

- Reduce Plant Air Leaks
- Adjust Manual Staging
- Use Unloading Controls
- Reduce System Pressure
- Sequence Compressors
- Reduce Run Time
- Add Primary Storage



Select Energy Efficiency Measures

Efficiency Measures

Facility: Main Facility Scenario: First EEM

System: Primary System

Data Entry Savings Summary

Description: First EEM

EEM Selection	Apply	Order	Edit
Reduce Air Leaks	<input checked="" type="checkbox"/>	1	
End Use Efficiency Improvements	<input checked="" type="checkbox"/>	2	
Reduce System Air Pressure	<input checked="" type="checkbox"/>	3	
Use Unloading Controls	<input checked="" type="checkbox"/>	4	
Adjust Staging	<input type="checkbox"/>		
Sequence Compressors	<input checked="" type="checkbox"/>	5	
Reduce Run Time	<input checked="" type="checkbox"/>	6	



Savings Summary Report

Efficiency Measures

Facility: Main Facility Scenario: First EEM
System: Primary System

Data Entry Savings Summary

Graph

Description	Peak Demand (kW)	Demand (\$)	Energy (kWh)	% Energy Use	Energy (\$)	Cost Savings (\$)	Installed Cost (\$)	Simple Payback (years)
Fix Leaks	14.5	755	79963	0.099	2399	3154	1000	0.3
Use efficient nozzles	26.2	1365	48638	0.06	1459	2824	800	0.3
Reduce Pressure	15.2	793	82646	10.3	2479	3272	100	0
Fix Unloading Controls	0	0	151791	18.9	4554	4554	1200	0.3
Add Sequencing	15.9	829	20345	2.5	610	1439	3000	2.1
Reduce Runtime	0	0	41517	5.2	1246	1246	0	0
TOTALS	71.7	3742	424901	52.8	1246	16489	6100	0.4



Life Cycle Analysis Setup Screen

Life Cycle Economics			
File Calculate Escalation Help			
<input type="radio"/> Project <input checked="" type="radio"/> Corporate		Depreciation Method: Straight line	Calc ? Exit
Costs		Default Escalation Rates	Financing
Capital costs (\$)	11,557	5.0 %	Date of loan (yr) 1998
Installation costs (\$)	155		Loan life (yrs) 0
Interest during construction (\$)	0		Loan interest rate (%) 10.0
Annual O&M cost (\$)	0	5.0 %	Discount rate (%) 18.0
Annual fuel cost (\$)	0	5.0 %	Property tax rate (%) 0.0
Fuel cost escalation rate table	*Use Default Value		Corporate tax rate (%) 35.0
Electricity Use and Cost		Default Escalation Rates	State income tax rate (%) 0.0
Project annual energy savings (kWh)	28,090		Project Life
Average energy cost (\$/kWh)	0.039330	3.0 %	Base year 1998
Electric cost escalation rate table	*Use Default Value		First year of operation 1998
Project demand reduction (kW)	3.2		Life expectancy (yrs) 15
Average demand cost (\$/kW)	3.67	5.0 %	Depreciation life (yrs) 5
Demand escalation rate table	*Use Default Value		Salvage value (\$) 0
Peak demand months	12		Junk value (\$) 0



Establish your Company Database

The screenshot shows a software window titled "Company Database" with a menu bar (File, Facilities, Help) and a toolbar with icons for file operations and help. Below the toolbar, there is a dropdown menu for "Company Database" currently set to "General FoodStuffs, Inc." and a "Browse" button. The main area is divided into two tabs: "Company Information" (active) and "Facility Ranking". The "Company Information" tab contains a form with the following fields:

- Name: General FoodStuffs, Inc.
- ID: (empty)
- Industry type: (dropdown menu)
- SIC code: (dropdown menu)
- Address 1: 1234 5th Ave W.
- Address 2: (empty)
- City: Des Moines
- State/Zip: WA 98123
- Contact: John Irving
- Phone: 206-923-4567
- Disk filename: AMSAMPLE.MDB



Facility Screen

Facility File Calculators Help

Facility: Main Facility

Facility Information

Facility Data

Facility name: Main Facility

Address 1: 1502 10th Ave SW

Address 2: Apt 32

City: Olympia

State/Zip: WA 1234567890

Contact: Bruce Whitney

Phone: 234

Total energy use, kWh: 1000

Units System

☒ English
☐ Metric

Compressor Summary

Utility Rate Data

Utility: Portland General Electric

Rate Schedule: Standard Residential

	Season 1	Season 2
Start month/day	01/15	06/15
Demand (\$/kW)	3.40	4.20
Energy Charge (\$/kWh)	Block 1: 0.044000 <input type="radio"/>	0.044000 <input type="radio"/>
	Block 2: 0.040000 <input checked="" type="radio"/>	0.038000 <input type="radio"/>
	Block 3: 0.040000 <input type="radio"/>	0.035000 <input checked="" type="radio"/>



Compressor Operations Summary

System Profiles

File Calculators Help

Cancel

Select:

Facility: Main Facility Daytype: Production

System: Primary System


System Data

Control range: 100.0 psi - 115.0 psi

	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Compressor														
100 hp Sullair														
Calc Power(kW)	72.0	72.0	72.0	72.0	72.0	72.0	84.0	84.0	84.0	84.0	84.0	84.0	90.0	90.0
Meas %Capacity	40.0	40.0	40.0	40.0	40.0	40.0	80.0	80.0	80.0	80.0	80.0	80.0	100.0	100.0
Calc AirFlow(acfm)	190	190	190	190	190	190	379	379	379	379	379	379	474	474
Sequence #	1	1	1	1	1	1	1	1	2	2	1	1	1	1
150 hp Worthington R														
Calc Power(kW)	20.0	20.0	20.0	20.0	20.0	20.0	56.8	56.8	56.8	56.8	56.8	56.8	92.5	92.5
Meas %Capacity							33.0	33.0	33.0	33.0	33.0	33.0	65.0	65.0
Calc AirFlow(acfm)							231	231	231	231	231	231	455	455
Sequence #	2	2	2	2	2	2	2	2	1	1	2	2	2	2
Total Power, kW	92.0	92.0	92.0	92.0	92.0	92.0	140.8	140.8	140.8	140.8	140.8	140.8	182.5	182.5
Total Airflow, acfm	190	190	190	190	190	190	610	610	610	610	610	610	929	929



Compressor Load Profile





Create a Maintenance Record

The screenshot displays the 'AirMaster - Maintenance' software window. The interface includes a title bar with standard window controls and a toolbar with icons for file operations and help. The main form is organized into several sections:

- Facility and System:** Two dropdown menus, 'Facility' (set to 'Main Facility') and 'System' (set to 'Primary System').
- Compressor:** A dropdown menu set to '100 hp Sullair'.
- Previous Actions:** An empty dropdown menu.
- Action Type:** A dropdown menu set to '- n/a -'.
- Action:** An empty dropdown menu.
- Date:** An empty text field.
- General Tab:** The active tab, containing:
 - Description:** A text input field.
 - Cost:** A text input field.
 - Parts:** A section with two radio buttons, 'Inspection Only' (selected) and 'Replacement'. Below them are fields for 'Description', 'Part No.', 'Unit Cost', and 'Unit'.
 - Last Maintenance Date:** A text input field.
 - Recommended Interval:** A text input field with radio buttons for 'Days' and 'Run-Hours'.
 - Inventory count:** A text input field.
- Notes:** A large text area on the right side of the General tab.
- Supplier:** A tab located above the Notes area.



Case Study: Compressed Air System

Lehigh Southwest Cement Company

- Stabilized system pressure, replaced worn compressors with more efficient units, reduced compressed air waste
- System now operates more efficiently with lower compressor capacity and at a lower system pressure
- Improved reliability and eliminated \$50,000/tear in emergency compressor rentals

Benefits:

- Annual savings of \$90,000 in energy costs plus \$59,000 in maintenance
- 175,000kWh saved annually
- Total cost: \$417,000 (\$90K incentive from SCE)
- Simple payback: 20 months



Case Study: Compressed Air System

Visteon Corporation

This manufacturer of a variety of structured metal parts for the automotive industry implemented an ongoing compressed air system leak management program. (Monroe, MI)

Recommendations

- Take 3 reciprocal compressors (totaling 1,550 hp) off line.
- Base load a 2,500-hp centrifugal compressor and use an 800-hp centrifugal compressor for peak needs.



Benefits

- Saves over \$560,000 per year in energy costs
- Reduces compressed air use by more than 50% per unit of production




Process Heating Assessment and Survey Tool

Assesses energy use in furnaces/
performance improvements.



U.S. Department of Energy
Energy Efficiency and Renewable Energy

Process Heating Assessment and Survey Tool (PHAST)





Process Heating Assessment and Survey Tool (PHAST)

What is PHAST?

- A tool that can be used to:
- Estimate annual energy use and energy cost for furnaces and boilers in a plant
- Perform detail heat balance and energy use analysis that identifies areas of energy use, efficiency and energy losses for a furnace
- Perform “what-if” analysis for possible energy reduction and efficiency improvements through changes in operation, maintenance and retrofits of components/systems
- Obtain information on energy saving methods and identify additional resources



Introduction

This section includes

- A number of calculators to assess effect of key furnace operating parameters on the furnace performance.
- Resources that provide additional-updated information.
 - A. Link to DOE-OIT and IHEA web sites
 - B. Glossary of terms used in process heating
 - C. Reference material related to process heating



Plant Equipment Information

The “**Plant Information**” section of PHAST is used to survey the process heating (PH) equipment used in a plant, estimate their energy use and cost and compare relative energy cost for all PH equipment.




Survey forms are used to collect energy use data for the furnaces, heaters etc.

1. The forms are used to collect information on process heating (PH) equipment energy supply and operating data that needs to be entered in various sections of PHAST
2. The survey forms are given as MS Excel spreadsheets.



Plant Energy Use and Cost Distribution Report*



The report shows

- Estimated annual energy use and estimate annual cost of energy for heating equipment (furnaces, ovens etc.)
- List of heating equipment and % of total energy cost used for each equipment in order of annual cost of energy used.

*** for the Surveyed Process Heating Equipment**




Furnace Heat Balance Analysis

- Analyze the energy used in various parts of a furnace under a given operating condition. The areas for energy use include charge or load, fixtures, trays etc., wall losses, water cooling losses, losses through openings and exposed hot parts, flue products (or exhaust gases) and heat storage.
- This section allows the user to identify major areas of energy use and the magnitude of losses to study the effect of changes in operating conditions and their effect on the energy used in the furnace.



Furnace Heat Balance

Energy Use – Losses Distribution



The report shows

- Analysis of energy used in various parts of a furnace under a given operating condition.



Reports

- This section provides two summary reports in the form of tables and charts.
- The Plant Summary report includes a table of energy used, expected cost of operation for the furnaces surveyed and their comparison.
- The Furnace Analysis report includes a table of energy used in various parts of the furnace analyzed, their relative importance in terms of the percentage of the total energy used and the effect of changes in key operating parameters on energy consumption for the furnace.



Case Study: Process Heating

Weirton Steel, Weirton, WV

Using the **PHAST** software, Weirton identified process heating opportunities in the Hot Dip Galvanizing Line and Hot Mill Reheat Furnaces.




Photo courtesy of Weirton Steel

Recommendations and Benefits

- Seven recommendations, including skid insulation, air-fuel control and slab preheating in reheat furnaces; reuse of reject heat; and direct-fire to replace steam
- Projected savings of \$1,500,000 per year



Steam System Assessment Tool

Profiles large steam system

Operations

Management.



Steam System Assessment Tool (SSAT)

- **PURPOSE:**
 - Demonstrate the magnitude of energy, cost, and emission savings related to specific steam system improvement opportunities
- **AUDIENCE:**
 - Engineers involved with operation and/or improvement of steam systems



You Can Use SSAT To Evaluate These Key Steam Improvement Initiatives

- Real Cost Of Steam
- Steam Quality
- Boiler Efficiency
- Alternative Fuels
- Cogeneration Opportunities
- Steam Turbines vs PRVs
- Boiler Blowdown
- Condensate Recovery
- Steam Trap Operating Efficiency
- Heat Recovery
- Vent Steam
- Steam Leaks
- Insulation Efficiency
- Emissions Calculations



Key SSAT Features

- Choice of 1, 2, or 3 Header Pressure Models
- Schematics of Model Steam systems
- Estimates of Site Environmental Emissions
- Major Equipment Simulated:
 - Boiler
 - Back pressure turbines
 - Condensing turbine
 - Deaerator
 - Steam traps, leaks, insulation losses
 - Letdowns
 - Flash vessels
 - Feedwater preheat exchangers



Six SSAT Worksheets

- Input
- Schematic of Baseline Model
- Projects Input
- Schematic of Projects Model
- Results
- User Calculations



Next steps

- Attend one-day end-user training to learn capabilities of ITP's software decision support tools and their use
- Or attend qualified specialist training to become a qualified trainer to teach others how to use PHAST. This is a 2 to 2 ½ days course offered at selected locations throughout the country
- Refer to DOE-EERE-ITP web page (www.eere.energy.gov/industry) for schedule and location in your area