MAURA HEALEY GOVERNOR

**KIM DRISCOLL** LIEUTENANT GOVERNOR

YVONNE HAO SECRETARY, HOUSING AND ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts **Division of Occupational Licensure Office of Public Safety and Inspections** 

1000 Washington Street, Suite 710 Boston, Massachusetts 02118

LAYLA R. D'EMILIA UNDERSECRETARY, CONSUMER AFFAIRS AND BUSINESS REGULATION

SARAH R. WILKINSON COMMISSIONER, DIVISION OF OCCUPATIONAL LICENSURE

## Agenda

Meeting of the **Board of Elevator Regulations** May 3, 2023, at 12:00 noon

Microsoft Teams meeting Join on your computer, mobile app or room device Click here to join the meeting Meeting ID: 260 181 603 128 Passcode: CBm4RE Download Teams | Join on the web

Or call in (audio only) +1 857-327-9245,,913075274# United States, Boston Phone Conference ID: 913 075 274#

- 1. Roll Call by Chair Eric Morse (pending new governor appointment or further Board action):
  - Eric Morse
  - Sarah Wilkinson
  - David Gaudet •
  - David Morgan •
  - Brian Ronan •
  - Christopher Towski •
  - Neil Mullane
  - Vacancy
  - Vacancy
- 2. Jason Tellier, TK Elevator **Product name: North American EOX** Petitioner is looking for product variance for new EOX product
- 3. MBTA Southcoast Rail RTE 18 Acushnet Avenue, New Bedford **New Installation**

Petitioner is seeking Relief from A17.1-2013, rule 2.11.10.1.1 metal fascia





- □ absent
- **p**resent □ absent
- **p**resent □ absent
  - □ absent
- **p**resent □ absent
- **p**resent □ absent
- **p**resent □ absent
  - □ absent

- **p**resent
- **p**resent

- **p**resent

requirement-substitute with glass fascia on two (new) elevators. The MBTA is required, per its settlement with the Boston Center for Independent Living, to provide maximum transparency of the elevator cab to promote safety through visibility. A solid panel of smooth steel fascia would negate the visibility so required. A smooth laminated glass fascia, exceeding the properties of the .055" thick smooth steel is proposed for use between the top of the MBTA pedestrian tunnel elevator door and the Street level in lieu of the smooth steel, for maximum visibility into the elevator cab. The remaining fascia would be smooth steel as required.

## 4. 238 West Main Street, Northborough State IDs: 215-P-11 and 215-P-36

Petitioner is requesting from 524 CMR a new waiver for one year (February 17, 2024) to meet the requirements of K351 to allow sprinklers to be installed in the facility hydraulic elevator shaft and the elevator hydraulic machine room.

- 5. Approval of meeting minutes from January 17, 2023, January 31, 2023, and February 14, 2023
- 6. <u>Old business (The Board may or may not discuss)</u>:
  - 267 Old Colony Avenue, Boston New Installation
    Petitioner was in front of the Board requesting a variance for a new installation of a semi-automated parking unit, 524 CMR 26.07 protection at other levels, 524 CMR 26.11 car enclosure and car gates. Placed on hold to come back in front of the Board with additional information.
  - 33 A Street, Boston
    - New Installation

Petitioner was in front of the Board requesting a variance for a new installation of a semi-automated parking unit, 524 CMR 26.07 protection at other levels, 524 CMR 26.11 car enclosure and car gates. Placed on hold to come back in front of the Board with additional information.

- Discussion regarding FS90 repairs and permit filing.
- 7. Matters not reasonably anticipated 48 hours in advance of meeting